



Product Service

Attestation of Conformity

No. N8A 16 07 75386 041

Holder of Certificate: **Shenzhen Kstar New Energy Company Limited**

The 9th Floor, R&D Building
Kstar Industrial Park, Guangming Hi-tech Industrial Zone
518107 Shenzhen, Guangdong Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(PV grid-interactive inverter)**

Model(s): **KSG-1K-SM, KSG-1.5K-SM,
KSG-2K-SM, KSG-3K-SM**

Parameters: Vmax PV: 500 Vd.c.
Nominal AC Frequency: 50 Hz
See page 2 for more details

Tested according to: EN 62109-1:2010
EN 62109-2:2011

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 64290160254801

Date, 2016-07-05


(Billy Qiu)



CE After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity

No. N8A 16 07 75386 041

Model	KSG-1K-SM	KSG-1.5K-SM	KSG-2K-SM	KSG-3K-SM
Vmax PV	500 Vd.c.	500 Vd.c.	500 Vd.c.	500 Vd.c.
Isc PV	13,2 Ad.c.	13,2 Ad.c.	13,2 Ad.c.	15,6 Ad.c.
Max. continuous output current	4,5 Aa.c.	7 Aa.c.	9 Aa.c.	14 Aa.c.
Max. continuous output power	1000 W	1500 W	2000 W	3000 W
Nominal AC Frequency	50 Hz	50 Hz	50 Hz	50 Hz
Nominal AC voltage	230 Va.c.	230 Va.c.	230 Va.c.	230 Va.c.
Power factor (full load)	>0,99	>0,99	>0,99	>0,99
Protective class	I	I	I	I
Ingress protection	IP65	IP65	IP65	IP65

Test report no.: 64290160254801

Date, 2016-07-05